



VERIFIED  
ZERO OZONE

Intertek does hereby certify that an independent assessment has been conducted on behalf of

# ATMOSAIR

**Certificate Number: 104058009GRR-009**

Certification Issued: 22 September 2020

Initial Verification Date: 22 September 2020

Certificate Valid Until: 21 September 2021

**Applicant Address:** 418 Meadow Street, Suite 204  
Fairfield, CT 06824 USA

**Product Category:** Appliances & Electronics, Air Cleaners

**Product Details:** See Appendix

**Conformance Criteria:** Conforms to UL 2998 (3rd Edition, July 10, 2020) clause 6.2, emittance of ozone not exceeding a concentration of 0.005 ppm.

**Issuing Office Name & Address:** Intertek Testing Services NA, Inc.  
4700 Broadmoor Ave SE, Suite 200  
Kentwood, MI 49512 USA  
Ph: +1-616-656-7401

Jesse Ondersma  
Certification Officer  
29 September 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



VERIFIED  
ZERO OZONE

Certificate Appendix

# ATMOSAIR

Certificate Number: 104058009GRR-009

<b>Product Category</b>	<b>Air Cleaner</b>
<b>Model Name(s)</b>	<b>FC-400</b>
<b>Product Restrictions</b>	<b>None</b>

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.